

Stenor
Fagertunveien 33
1357 Bekkestua

Report Program 1

22.08.2025

Customer No.: 1
Nor Tekstil
Industrivegen 24
6905 Florø

Site No.: 117
Skedsmo
Morten Bodding
Høgslundveien 15
2020 Skedsmokorset

Measurement from 21.08.2025 14:27:52


Device type:	MRU OPTIMA
Serial number:	359604
Firmware version:	3.00.15
Fuel:	Sample gas
O2 Ref.:	5 %
CO2max:	0 %

O2	%	2,84	CO	mg/m ³	1
NO	mg/m ³	103	NO2	mg/m ³	6
NOx	mg/m ³	164	T-air	°C	216,4

Comment

Fyrkjel | Last 60% | Port lukket

History of measurement from 21.08.2025 14:27:52



Date:

Signature: