

## Declaration of exemption pursuant to § 27-12 of the Norwegian Pollution Control Regulations (forurensningsforskriften)

*PolarDC Her AS*

*Data center – HER01*

In connection with the application for a permit for a new polluting activity for data center at Herøya Industripark, it is assumed that the emergency power units are covered by Chapter 27 of the Norwegian Pollution Control Regulations regarding emissions to air from medium-sized combustion plants.

In accordance with § 27-12, third paragraph, of the Norwegian Pollution Control Regulations, this document declares that the emergency generators operated by PolarDC Her AS have less than 500 operating hours per year. The purpose of the generators are to work as an emergency power supply in the event of a possible power failure. As such, the generators are exempt from the emission limit values stipulated in § 27-12.


The signatory of the declaration is responsible for ensuring that the emergency power generators operate for less than 500 hours per year.

PolarDC Her AS

Date: 5 December 2025

Name: Thomas Chubb

Title: Director/Board member

Signature:  Signed by:  
B56C4F57205A469...